

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Anuj Kumar, Junior Engineer

(Name of Officers with designation) from U.P. Jal Nigam (R), Baghpat PHED

inspected the Delhi Public School, Baghpat

(Name & Address of the school) on 27-03-2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. C/25/03/120 dated 28-03-2025

of U.P. Jal Nigam (R), Baghpat, Lab (PHED Lab) certified that the

Delhi Public School, Baghpat (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 27-03-2026


Assistant Engineer
Division Office, U.P. Jal Nigam (Rural)
Baghoat

Signature with Seal:

Name : Deepak Kumar

Designation : Assistant Engineer

Name & Address of the Office / Department :


Executive Engineer, Divisional office

U.P. Jal Nigam (R), Baghpat

To
DELHI PUBLIC SCHOOL
BAGHPAT

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Ragini Chaudhary
Principal
Delhi Public School


Manager
Delhi Public School Baghpat



District Level Water Analysis Laboratory U.P Jal Nigam(Rural) Baghpat

TEST REPORT (WATER)

Report No:	C/25/03/120	Issue Date:	28-03-2025	Page No 01/1
Cont. Person:	Mr. Sunil Kumar (Q.M)	Address:	District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural) Baghpat	
Office Name and Address	Customer Details			
Ref Letter No & Date				
Basic details of sample				
District	Baghpat	Block	Khekra	
Gram Panchayat	Jahangirpur Urf Dundahera	Village/Mohalla	Jahangirpur Urf Dundahera	
Habitation	Jahangirpur Urf Dundahera	Location/Site Name	DPS DUNDA HERA BAGHIPAT	
Water Source	RO	Sample Code:	C/25/03/120	
Quantity of Sample(ml)	1000 ml	Date of S.C.	27-03-2025	
Receiving Date	27-03-2025	S. Collector	JE	
Sample Depositor	JE	Sampling Method		
Analysis Start Date	28-03-2025	Analysis Completion Date:	28-03-2025	

	Analyzed parameters	unit	Observed value	Specified Values as per BIS 10500 (2017)		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH @ 25°C	-	7.02	6.5-8.5	6.5-8.5	IS 3025(Part 11): 2022
2	Total Dissolved Solids	mg/L	250	500	2000	IS 3025(Part 16): 2023
3	Turbidity	NTU	—	1.0	5.0	IS 3025 (Pt 10): 2023
4	Chloride	mg/L	11	250	1000	IS 3025(Part 32): 2019
5	Total Alkalinity	mg/L	122	200	600	IS 3025(Part 23): 2023
6	Total Hardness	mg/L	130	200	600	IS 3025(Part 21): 2019
7	Nitrate	mg/L	6.24	45.0	45.0	APHA 24 th Edition 4500- NO ₃ Method-D(UV Screening): 2023
8	Fluoride	mg/L	—	1.0	1.5	APHA 24 th Edition 4500- F Method-C (Electrode Method): 2023
9	Calcium	mg/L	12.8	75.0	200	IS 3025(Part 40): 2019
10	Magnesium	mg/L	23.8	30.0	100	IS 3025(Part 46): 2023 (Calculation Method)
11	Iron	mg/L	0.11	1.0	1.0	APHA 24 th Edition 3500- Fe Method-B (1,10Phenanthroline): 2023
12	Colour	Hazen	2.0	5.0	15.0	IS 3025(Part 4): 2021
13	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025(Part 5): 2022
14	Sulphate	mg/L	18.6	200	400	IS 3025 (Part 24): 2022
15	E.coli*	CFU	N.T	Shall not be detected in 100 ml Sample	Shall not be detected in 100 ml Sample	IS 15185 (2016)
16	Total Coliform*	CFU	N.T	Shall not be detected in 100 ml Sample	Shall not be detected in 100 ml Sample	IS 15185 (2016)

* These Parameter are out of NABL Scope. B.D.L- Below Detection limit, N.T- Not Tested

Note:

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from head of laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of test reports unless otherwise specified.

Prepared by	Reviewed & Authorized by
Nukul (Deputy Technical Manager)	Sunil Kumar (Quality Manager)

Laboratory contact details: Email Id....baghpatlab6452@gmail.com

***** End of the Report *****

Ragini Chaudhary
Principal
Delhi Public School

Manager
Delhi Public School Baghpat